Austrian Institute of Construction Engineering Schenkenstrasse 4 | T+43 1 533 65 50 1010 Vienna I Austria | F+43 1 533 64 23 www.oib.or.at I mail@oib.or.at





European Technical Assessment

ETA-09/0036 of 21.04.2023

General part

Technical Assessment Body issuing the European Technical Assessment	Österreichisches Institut für Bautechnik (OIB) Austrian Institute of Construction Engineering
Trade name of the construction product	MM – crosslam
Product family to which the construction product belongs	Solid wood slab elements to be used as structural elements in buildings
Manufacturer	Mayr-Melnhof Holz Holding AG Turmgasse 67 8700 Leoben Austria
Manufacturing plant	Mayr-Melnhof Holz Gaishorn GmbH Gaishorn 182 8783 Gaishorn am See Austria
	Mayr-Melnhof Holz Leoben GmbH Turmgasse 67 8700 Leoben Austria
This European Technical Assessment contains	21 pages including 5 Annexes which form an integral part of this assessment.
This European Technical Assessment is issued in accordance with Regulation (EU) No 305/2011, on the basis of	European Assessment Document (EAD) 130005-00-0304 "Solid wood slab element to be used as a structural element in buildings".
This European Technical Assessment replaces	European Technical Assessment ETA-09/0036 of 02.09.2020.



Remarks

Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may be made with the written consent of Austrian Institute of Construction Engineering. Any partial reproduction has to be identified as such.

Specific parts

1 Technical description of the product

1.1 General

This European Technical Assessment¹ (ETA) applies to the cross laminated timber "MM - crosslam". MM - crosslam is made of softwood boards which are bonded together in order to form cross laminated timber (solid wood slab elements). Generally, adjacent layers of the softwood boards are arranged perpendicular (angle of 90°) to each other, see Annex 1, Figure 1.

The principle structure of the cross laminated timber is shown in Annex 1, Figure 2 and Figure 3. Surfaces are planed.

The solid wood slab elements consist of at least three and up to thirteen adjacent layers which are arranged perpendicular to each other. With regard to the thickness of the solid wood slab element, thickness and orientation of individual layers are symmetrically assembled. In case of serious deviations from symmetry potential effects should be investigated.

In multilayer elements with at least five layers, a maximum of two consecutive board layers may be arranged in the same direction if their all over thickness does not exceed 90 mm.

Single board layers (maximum 50 % of the cross section) may be replaced by one- and multilayer solid wood panels. The solid wood panels shall be suitable for structural use.

The surfaces of the solid wood slabs may be provided with wood based panels.

MM – crosslam and the boards for its manufacturing correspond to the specifications given in the Annexes 1 and 2. The material characteristics, dimensions and tolerances of MM – crosslam, not indicated in these Annexes, are given in the technical file² of the European Technical Assessment.

The application of wood preservatives and flame retardants is not subject of the European Technical Assessment.

1.2 Components

1.2.1 Boards

The specification of the boards is given in Annex 2, Table 2. Boards are visually or machine strength graded. Only technically dried wood shall be used.

Wood species is European spruce or equivalent softwood.

constancy of performance procedure, is handed over to the notified product certification body.

1.2.2 Wood-based panels

ETA-09/0036 of 21.04.2023.

Wood-based panels are in accordance with EN 13986 or a European Technical Assessment.

The ETA-09/0036 was firstly issued in 2009 as European technical approval with validity from 23.03.2009, extended in 2013 with validity from 17.06.2013, amended and converted in 2015 to the European Technical Assessment ETA-09/0036 of 30.06.2015, amended in 2020 to the European Technical Assessment ETA-09/0036 of 15.01.2020, amended in 2020 to the European Technical Assessment ETA-09/0036 of 02.09.2020 and amended in 2023 to the European Technical Assessment

The technical file of the European Technical Assessment is deposited at Österreichisches Institut für Bautechnik and, in so far as is relevant to the tasks of the notified product certification body involved in the assessment and verification of



1.2.3 Adhesive

The adhesive for bonding of the cross laminated timber and the finger joints of the individual boards shall conform to EN 301 or EN 15425.

2 Specification of the intended use(s) in accordance with the applicable European Assessment Document (thereafter EAD)

2.1 Intended use

The solid wood slab is intended to be used as a structural or non-structural element in buildings and timber structures.

The solid wood slab shall be subjected to static and quasi-static actions only.

The solid wood slab is intended to be used in service classes 1 and 2 according to EN 1995-1-1³. Members which are directly exposed to the weather shall be provided with an effective protection for the solid wood slab element in service.

2.2 General assumptions

The solid wood slab elements are manufactured in accordance with the provisions of the European Technical Assessment using the manufacturing process as identified in the inspection of the manufacturing plant by Österreichisches Institut für Bautechnik and laid down in the technical file.

The manufacturer shall ensure that the requirements in accordance with the Clauses 1, 2 and 3 as well as with the Annexes of the European Technical Assessment are made known to those who are concerned with design and execution of the works.

Layers of planed boards shall be bonded together to the required thickness of the cross laminated timber. The individual boards shall be jointed in longitudinal direction by means of finger joints according to EN 14080, there shall be no butt joints.

Adhesive shall be applied on one face of each board. The edges of the boards need not to be bonded.

<u>Design</u>

The European Technical Assessment only applies to the manufacture and use of cross laminated timber. Verification of stability of the works including application of loads on the cross laminated timber is not subject to the European Technical Assessment.

The following conditions shall be observed:

- Design of cross laminated timber members is carried out under the responsibility of an engineer experienced in such products.
- Design of the works shall account for the protection of the cross laminated timber.
- The cross laminated timber members are installed correctly.

Design of cross laminated timber members elements may be according to EN 1995-1-1 and EN 1995-1-2, taking into account of Annexes 2 and 3 of the European Technical Assessment.

Standards and regulations in force at the place of use shall be considered.

Packaging, transport, storage, maintenance, replacement and repair

Concerning product packaging, transport, storage, maintenance, replacement and repair it is the responsibility of the manufacturer to undertake the appropriate measures and to advise his clients on the transport, storage, maintenance, replacement and repair of the product as he considers necessary.

electronic copv



Installation

It is assumed that the product will be installed according to the manufacturer's instructions or (in absence of such instructions) according to the usual practice of the building professionals.

2.3 Assumed working life

The provisions made in the European Technical Assessment (ETA) are based on an assumed intended working life of MM – crosslam of 50 years, when installed in the works, provided that the cross laminated timber elements are subject to appropriate installation, use and maintenance (see Clause 2.2). These provisions are based upon the current state of the art and the available knowledge and experience⁴.

The indications given as to the working life of the construction product cannot be interpreted as a guarantee neither given by the product manufacturer or his representative nor by EOTA nor by the Technical Assessment Body, but are regarded only as a means for choosing the appropriate products in relation to the expected economically reasonable working life of the works.

3 Performance of the product and reference to the methods used for its assessment

3.1 Essential characteristics of the product

Table 1: Essential characteristics of the product and assessment methods

Nº	Essential characteristic	Product performance				
	Basic requirement for construction works 1: Mechanical resistance and stability ¹⁾					
1	Bending ²⁾	Annex 2				
2	Tension and compression ²⁾	Annex 2				
3	Shear ²⁾	Annex 2				
4	Embedment strength	Annex 2				
5	Creep and duration of the load	Annex 2				
6	Dimensional stability	Annex 2				
7	In-service environment	Annex 2				
8	Bond integrity	Annex 2				
	Basic requirement for construction works 2	: Safety in case of fire				
9	Reaction to fire	Annex 2				
10	Resistance to fire	Annex 2				
	Basic requirement for construction works 3: Hygien	e, health and the environment				
11	Content, emission and/or release of dangerous substances	3.1.1				
12	Water vapour permeability – Water vapour transmission	Annex 2				
	Basic requirement for construction works 4: Saf	ety and accessibility in use				
13	Impact resistance	Annex 2				

⁴ The real working life of a product incorporated in a specific works depends on the environmental conditions to which that works is subject, as well as on the particular conditions of the design, execution, use and maintenance of that works. Therefore, it cannot be excluded that in certain cases the real working life of the product can also be shorter than the assumed working life.



N⁰	Essential characteristic	Product performance				
	Basic requirement for construction works 5: Protection against noise					
14	Airborne sound insulation No performance assessed.					
15	5 Impact sound insulation No performance assessed.					
16	6 Sound absorption No performance asse					
	Basic requirement for construction works 6: Energ	y economy and heat retention				
17	17 Thermal conductivity Annex 2					
18						
19						
¹⁾ These characteristics also relate to basic requirement for construction works 4.						

²⁾ Load bearing capacity and stiffness regarding mechanical actions perpendicular to and in plane of the solid wood slab element.

3.1.1 Hygiene, health and the environment

The release of dangerous substances is determined according to EAD 130005-00-0304, "Solid wood slab element to be used as a structural element in buildings". No dangerous substances is the performance of the MM – crosslam in this respect.

NOTE In addition to the specific clauses relating to dangerous substances contained in the European Technical Assessment, there may be other requirements applicable to the products falling within its scope (e.g. transposed European legislation and national laws, regulations and administrative provisions). In order to meet the provisions of the Construction Products Regulation, these requirements need also to be complied with, when and where they apply.

3.2 Assessment methods

3.2.1 General

The assessment of the essential characteristics in Clause 3.1 of MM – crosslam for the intended use, and in relation to the requirements for mechanical resistance and stability, for safety in case of fire, for hygiene, health and the environment, for safety and accessibility in use, for protection against noise and for energy economy and heat retention in use in the sense of the basic requirements for construction works Nº 1 to 6 of Regulation (EU) Nº 305/2011 has been made in accordance with the European Assessment Document EAD 130005-00-0304, Solid wood slab element to be used as a structural element in buildings.

3.2.2 Identification

The European Technical Assessment for MM – crosslam is issued on the basis of agreed data that identify the assessed product. Changes to materials, to composition, to characteristics of the product, or to the production process could result in these deposited data being incorrect. Österreichisches Institut für Bautechnik should be notified before the changes are implemented, as an amendment of the European Technical Assessment is possibly necessary.



4 Assessment and verification of constancy of performance (thereafter AVCP) system applied, with reference to its legal base

4.1 System of assessment and verification of constancy of performance

According to Commission Decision 97/176/EC the system of assessment and verification of constancy of performance to be applied to MM – crosslam is System 1. System 1 is detailed in Commission Delegated Regulation (EU) № 568/2014 of 18 February 2014, Annex, 1.2., and provides for the following items

- (a) The manufacturer shall carry out
 - (i) factory production control;
 - (ii) further testing of samples taken at the manufacturing plant by the manufacturer in accordance with a prescribed test plan⁵;
- (b) The notified product certification body shall decide on the issuing, restriction, suspension or withdrawal of the certificate of constancy of performance of the construction product on the basis of the outcome of the following assessments and verifications carried out by that body:
 - an assessment of the performance of the construction product carried out on the basis of testing (including sampling), calculation, tabulated values or descriptive documentation of the product;
 - (ii) initial inspection of the manufacturing plant and of factory production control;
 - (iii) continuous surveillance, assessment and evaluation of factory production control.

4.2 AVCP for construction products for which a European Technical Assessment has been issued

Notified bodies undertaking tasks under System 1 shall consider the European Technical Assessment issued for the construction product in question as the assessment of the performance of that product. Notified bodies shall therefore not undertake the tasks referred to in point 4.1 (b)(i).

5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable European Assessment Document

5.1 Tasks for the manufacturer

5.1.1 Factory production control

In the manufacturing plant the manufacturer shall establish and continuously maintain a factory production control. All procedures and specification adopted by the manufacturer shall be documented in a systematic manner. The factory production control shall ensure the constancy of performances of MM – crosslam with regard to the essential characteristics.

The manufacturer shall only use raw materials supplied with the relevant inspection documents as laid down in the control plan. The incoming raw materials shall be subject to controls by the manufacturer before acceptance. Check of incoming materials shall include control of inspection documents presented by the manufacturer of the raw materials.

The frequencies of controls conducted during manufacturing and on the assembled product are defined by taking account of the manufacturing process of the product and are laid down in the control plan.

The prescribed test plan has been deposited with Österreichisches Institut für Bautechnik and is handed over only to the notified product certification body involved in the procedure for the assessment and verification of constancy of performance. The prescribed test plan is also referred to as control plan.



The results of factory production control are recorded and evaluated. The records include at least the following data:

- Designation of the product, basic materials and components
- Type of control or test
- Date of manufacture of the product and date of testing of the product or basic materials or components
- Results of controls and tests and, if appropriate, comparison with requirements
- Name and signature of person responsible for factory production control

The records shall be kept at least for ten years time after the construction product has been placed on the market and shall be presented to the notified product certification body involved in continuous surveillance. On request they shall be presented to Österreichisches Institut für Bautechnik.

5.1.2 Declaration of performance

The manufacturer is responsible for preparing the declaration of performance. When all the criteria of the assessment and verification of constancy of performance are met, including the certificate of conformity issued by the notified product certification body, the manufacturer shall draw up a declaration of performance.

5.2 Tasks for the notified product certification body

5.2.1 Initial inspection of the manufacturing plant and of factory production control

The notified product certification body shall verify the ability of the manufacturer for a continuous and orderly manufacturing of MM – crosslam according to the European Technical Assessment. In particular the following items shall be appropriately considered

- Personnel and equipment
- The suitability of the factory production control established by the manufacturer
- Full implementation of the control plan
- 5.2.2 Continuous surveillance, assessment and evaluation of factory production control

The notified product certification body shall visit the factory at least once a year for routine inspection. In particular the following items shall be appropriately considered

- The manufacturing process including personnel and equipment
- The factory production control
- The implementation of the control plan


The results of continuous surveillance are made available on demand by the notified product certification body to Österreichisches Institut für Bautechnik. When the provisions of the European Technical Assessment and the control plan are no longer fulfilled, the certificate of constancy of performance is withdrawn by the notified product certification body.

Issued in Vienna on 21.04.2023 by Österreichisches Institut für Bautechnik

The original document is signed by:

Rainer Mikulits Managing Director







Characteristic Dimension / Specification					
Cross laminated timber					
Thickness	mm	36 to	360		
Width	m	≤ <i>4</i>	l.0		
Length	m	≤ 1	8.0		
Number of layers		3 to symmetric			
Char. density ρ _k	kg/m³	1.1 >	(ρ _{ι,k}		
Maximum width of joints between boards within one layer	mm	זיי max. 10 % ≤ 4 mm			
Во	ard				
Surface		planed			
Thickness (planed dimension)	mm	12 to 45			
Width	mm	70 to 280			
Ratio width to thickness	—	≥ 2 : 1			
Boards shall be graded with suitable visual and/or machine procedures to be able to assign them to a strength class according to EN 338.					
Cover layer	—	C16 / T11 to	C35 / T21 ¹⁾		
Inner layer		$\leq 30 \ \% \ C16 \ / \ T11 \ ^2) \\ \geq 70 \ \% \ C_{\text{Dl}} \ ^{3), \ 2)}$	≤ 30 % C24 / T14 ⁴ ≥ 70 % C35 / T21 ⁴		
Moisture of wood according to EN 13183-2	%	6 to 15 % Within one member of CLT the moisture content shall not differ by more than 5 %.			
Finger joints		EN 1	4080		

³⁾ Strength class of the cover layer.

⁴⁾ If the boards of the cover layer confirm to the strength class C35 / T21.

	MM – crosslam	Annex 2
Ch	aracteristic data of cross laminated timber	of European Technical Assessment ETA-09/0036 of 21.04.2023



	Table 3: Product characteristics of the solid wood slab				
BWR	Essential characteristic	Assessme	ent method	Level / Cl	ass / Description
1	Mechanical resistance and stability				
	1. Mechanical actions perpendicular to cross laminated timber				
	Strength class of boards	EN 338		C16 / T	11 to C35 / T21
	Modulus of elasticity				
	 parallel to the grain of the boards $E_{0, mean}$ 	<i>I_{eff}</i> , Annex 3 EAD 13000 2.2.1.1		C16 / T11 C18 / T11 C24 / T14 C30 / T18 C35 / T21	8 000 MPa 9 000 MPa 12 000 MPa 12 600 MPa 13 700 MPa
	 perpendicular to the grain of the boards $E_{90, mean}$ 	EN 338		C16 / T11 C18 / T11 C24 / T14 C30 / T18 C35 / T21	270 MPa 300 MPa 370 MPa 400 MPa 430 MPa
	Shear modulus				
	 parallel to the grain of the boards $G_{090, mean}$ 	EN 338		C16 / T11 C18 / T11 C24 / T14 C30 / T18 C35 / T21	500 MPa 560 MPa 690 MPa 750 MPa 810 MPa
	 perpendicular to the grain of the boards (rolling shear modulus) <i>G</i>_{9090, mean} 	EAD 13000 2.2.1.1 and			50 MPa
	Bending strength				
	 parallel to the grain of the boards $f_{m, k}$ 	<i>W_{eff}</i> , Annex EAD 13000 2.2.1.1		C16 / T11 C18 / T11 C24 / T14 C30 / T18 C35 / T21	1/k _{sys} · 17.6 MPa ⁵⁾ 1/k _{sys} · 19.8 MPa ⁵⁾ 1/k _{sys} · 26.4 MPa ⁵⁾ 1/k _{sys} · 33.0 MPa ⁵⁾ 1/k _{sys} · 38.5 MPa ⁵⁾
	Tensile strength				
	- perpendicular to the grain of the boards $f_{t, 90, k}$	EN 338, reduced		C	.12 MPa
⁵⁾ k _{sys}	$m = \max\{1.0; 1.1 - 0.025 \cdot n\}$	n	number of board	ls within cover laye	er
	MM – crosslam		Annex 2		
Cha	racteristic data of cross laminated	timber	of European	Technical Ass	essment

MM – crosslam	Annex 2
Characteristic data of cross laminated timber	of European Technical Assessment ETA-09/0036 of 21.04.2023



BWR	Essential characteristic	Assessment method	Level / Class / Description
	Compressive strength		
	 perpendicular to the grain of the boards <i>f_c</i>, 90, <i>k</i> 	EN 338	C16 / T11 2.2 MPa C18 / T11 2.2 MPa C24 / T14 2.5 MPa C30 / T18 2.7 MPa C35 / T21 2.7 MPa
	Shear strength		
	 parallel to the grain of the boards $f_{v, 090, k}$ 	EN 338	C16 / T113.2 MPaC18 / T113.4 MPaC24 / T144.0 MPaC30 / T184.0 MPaC35 / T214.0 MPa
	 perpendicular to the grain of the boards (rolling shear strength) <i>f_v</i>, <i>9090</i>, <i>k</i> 	A _{gross} , Annex 3 EAD 130005-00-0304, 2.2.1.3	1.10 MPa

MM – crosslam	Annex 2
Characteristic data of cross laminated timber	of European Technical Assessment ETA-09/0036 of 21.04.2023



/R	Essential characteristic	Assessment method	Level / Class	/ Description
	Mechanical resistance and sta	bility		
	2. Mechanical actions in plane	of cross laminated tim	ber	
	Strength class of boards	EN 338	C16 / T11 to	o C35 / T21
	Modulus of elasticity			
	– parallel to the grain of the boards $E_{0, mean}$	<i>A_{net}, I_{net}</i> , Annex 3 EAD 130005-00-0304, 2.2.1.1	C18 / T11 9 C24 / T14 1 C30 / T18 1	000 MPa 000 MPa 2 000 MPa 2 600 MPa 3 700 MPa
	Shear modulus			
	- parallel to the grain of the boards $G_{090, mean}$	A _{net} , Annex 3 EAD 130005-00-0304, 2.2.1.3	450	MPa
	Bending strength			
	- parallel to the grain of the boards $f_{m, k}$	<i>W_{net}</i> , Annex 3 EAD 130005-00-0304, 2.2.1.1	C18 / T11 1 C24 / T14 2 C30 / T18 3	6 MPa 8 MPa 24 MPa 30 MPa 35 MPa
	Tensile strength			
	 parallel to the grain of the boards <i>f</i>_t, <i>o</i>, <i>k</i> 	EN 338	C18 / T11 1 C24 / T14 1 C30 / T18 1	8.5 MPa 0.0 MPa 4.5 MPa 9.0 MPa 22.5 MPa
	Compressive strength			
	 parallel to the grain of the boards <i>f_{c, 0, k}</i> 	EN 338	C18 / T11 1 C24 / T14 2 C30 / T18 2	7 MPa 8 MPa 21 MPa 24 MPa 25 MPa
	Shear strength			
	- parallel to the grain of the boards $f_{v, 090, k}$	A _{net} , Annex 3 EAD 130005-00-0304, 2.2.1.3	5.0 1	ИРа

MM – crosslam	Annex 2
Characteristic data of cross laminated timber	of European Technical Assessment ETA-09/0036 of 21.04.2023



Essential characteristic	Assessment method	Level / Class	/ Description	
3. Other mechanical actions				
Creep and duration of load	k_{mod} and k_{def} according to EN 1995-1-1 for glued laminated timber			
Dimensional stability Moisture content during service shall not change to such an extend that ac deformation will occur.				
In-service environment				
Durability of timber	EN 1995-1-1			
Service classes		1 ar	nd 2	
Bond integrity	EAD 130005-00-0304	Pa	ISS	
Safety in case of fire		l		
Reaction to fire				
Glued laminated timber products	2005/610/EC ≥ 380 kg/m ³		kg/m ³	
Euroclass D-s2, d0				
structures with specified fire resistance	EN 13501-2	Annex 3		
Charring rate for MUF		Floor/Roof	Wall	
Charring of the cover layerCharring of more layers than the cover layer	EAD 130005-00-0304	0.65 mm/min 0.76 mm/min ⁶⁾	0.60 mm/min 0.71 mm/min	
Charring rate for PU		Floor/Roof	Wall	
Charring of the cover layerCharring of more layers than the cover layer	EAD 130005-00-0304	0.65 mm/min 1.3 mm/min ⁶⁾	0.63 mm/min 0.86 mm/min	
25 mm of charring. Afterwards the charri	ng rate 0.65 mm/min applies u	p to the next glue line.		
	 3. Other mechanical actions Creep and duration of load Dimensional stability Moisture content during servideformation will occur. Embedment strength In-service environment Durability of timber Service classes Bond integrity Safety in case of fire Reaction to fire Glued laminated timber products Resistance to fire Structures with specified fire resistance Charring of the cover layer Charring of more layers than the cover layer Charring of more layers than the cover layer 	3. Other mechanical actions Creep and duration of load kmod and kdef according to timber Dimensional stability Moisture content during service shall not change to deformation will occur. Embedment strength Embedment strength according to EN 1995-cover layer shall be take In-service environment EN 1995-1-1 Durability of timber EN 1995-1-1 Service classes EAD 130005-00-0304 Safety in case of fire Commission Decision 2005/610/EC Reaction to fire Commission Decision 2005/610/EC Glued laminated timber products EN 13501-2 Charring rate for MUF EAD 130005-00-0304 - Charring of the cover layer EAD 130005-00-0304 - Charring of the cover layer EAD 130005-00-0304 - Charring of the cover layer EAD 130005-00-0304	3. Other mechanical actions Creep and duration of load kmod and kdef according to EN 1995-1-1 for timber Dimensional stability Moisture content during service shall not change to such an exter deformation will occur. Embedment strength Embedment strength of fasteners may according to EN 1995-1-1. The directior cover layer shall be taken as reference. In-service environment EN 1995-1-1 Durability of timber EN 1995-1-1 Service classes 1 ar Bond integrity EAD 130005-00-0304 Pa Safety in case of fire Exestion to fire Glued laminated timber products Commission Decision 2005/610/EC ≥ 380 Extructures with specified fire resistance EN 13501-2 Ann Charring of the cover layer EAD 130005-00-0304 0.65 mm/min 0.76 mm/min ⁶) Charring rate for PU EAD 130005-00-0304 0.65 mm/min 0.76 mm/min ⁶) Charring of the cover layer EAD 130005-00-0304 0.65 mm/min 0.76 mm/min ⁶)	

MM – crosslam	Annex 2
Characteristic data of cross laminated timber	of European Technical Assessment ETA-09/0036 of 21.04.2023



BWR	Essential characteristic	Assessment method	Level / Class / Description			
3	Hygiene, health and environment					
	Vapour permeability, μ , for wood	EN ISO 10456	50 (dry) to 20 (wet)			
4	Safety and accessibility in use)				
	Impact resistance	Soft body resistance is assumed to be fulfilled for walls with a minimum of 3 layers and minimum thickness of 60 mm.				
6	Energy economy and heat rete	ention				
	Thermal conductivity, λ , of wood	EN ISO 10456	0.12 W/(m·K)			
	Thermal inertia, specific heat capacity c_p , of wood	EN ISO 10456	1 600 J/(kg⋅K)			

MM – crosslam	Annex 2
Characteristic data of cross laminated timber	of European Technical Assessment ETA-09/0036 of 21.04.2023



Examples with specified fire resistance

Wall structures

Cladding on the fire exposed side	Mounting	CLT element	Test load	Tested wall height	Classifi- cation
		Designation and structure [mm]	[kN/m]	[m]	i => 0
-	-	MM-crosslam 100 3s	35	3	REI 60
		40-20-40			
-	-	MM-crosslam 100 5s	35	3	REI 60
		20-20-20-20-20			
12.5 mm gypsum plasterboard	Drywall screws	MM-crosslam 80 3s	35	3	REI 60
type DF according to EN 520, ρ ≥ 800 kg/m³	3.9 mm x 35 mm with a = 75/150 mm (edge/centre) row distance 625 mm	30-20-30			

Cladding on the fire exposed side	Mounting	CLT element	Test load	Tested wall height	Classifi cation
		Designation and structure [mm]	[kN/m]	[m]	i => o
2 x 15 mm gypsum plasterboard type DF according to EN 520, $\rho \ge 800 \text{ kg/m}^3$	First layer: ribbed nails I = 40 mm Second layer: ribbed nails I = 40 mm (left side) and staples I = 45 mm (right side) with a = 75/150 mm (edge/centre) row distance 625 mm	MM-crosslam 80 3s 30-20-30	-	3	EI 90
12.5 mm gypsum plasterboard type DF according to EN 520, $\rho \ge 800 \text{ kg/m}^3$	Drywall screws 3.9 mm x 35 mm with a = 75/150 mm (edge/centre) row distance 625 mm	MM-crosslam 100 3s 40-20-40	35	3	REI 90
12.5 mm gypsum plasterboard type DF according to EN 520, $\rho \ge 800 \text{ kg/m}^3$ 40 mm mineral wool according to ÉN 13162, $\rho = 11 \text{ kg/m}^3$	Drywall screws 3.9 mm x 35 mm with a = 75/150 mm (edge/centre) row distance 625 mm	MM-crosslam 100 3s 40-20-40	35	3	REI 90
12.5 mm gypsum plasterboard type DF according to EN 520, $\rho \ge 800 \text{ kg/m}^3$	Drywall screws 3.9 mm x 35 mm with a = 75/150 mm (edge/centre) row distance 625 mm	MM-crosslam 100 5s 20-20-20-20-20	35	3	REI 90

MM – crosslam	Annex 3
Resistance to fire	of European Technical Assessment ETA-09/0036 of 21.04.2023



Cladding on the fire exposed side	Mounting	CLT element	Test load	Tested wall height	Classifi- cation
		Designation and structure [mm]	[kN/m]	[m]	i => o
12.5 mm gypsum plasterboard type DF according to EN 520, $\rho \ge 800 \text{ kg/m}^3$ 40 mm mineral wool according to ÉN 13162, $\rho = 11 \text{ kg/m}^3$	Drywall screws 3.9 mm x 35 mm with a = 75/150 mm (edge/centre) row distance 625 mm	MM-crosslam 100 3s 40-20-40	35	3	REI 120

Floor structures

Cladding on the fire exposed side	Mounting	CLT element	Test load	Tested span	Classifi- cation
		Designation and structure [mm]	[kN/m²]	[m]	b => a
-	-	MM-crosslam 140 5s 40-20-20-20-40	5	5	REI 60
12.5 mm gypsum plasterboard type DF according to EN 520, $\rho \ge 800 \text{ kg/m}^3$	Drywall screws 3.9 mm x 35 mm with a = 75/150 mm (edge/centre) row distance 625 mm	MM-crosslam 100 3s 40-20-40	0.6	5	REI 60

Cladding on the fire exposed side	Mounting	CLT element	Test load	Tested span	Classifi- cation
		Designation and structure [mm]	[kN/m²]	[m]	b => a
-	-	MM-crosslam 160 5s	6	5	REI 90
		40-20-40-20-40			
12.5 mm gypsum plasterboard type	Drywall screws	MM-crosslam 140 5s	-	5	EI 90
DF according to EN 520, ρ ≥ 800 kg/m³	3.9 mm x 35 mm with a = 75/150 mm (edge/centre) row distance 625 mm	40-20-20-20-40			
35 mm wood wool board Heraklith	Heraklith screws	MM-crosslam 160 5s	-	5	EI 90
EPV type L2-W1-T2-S2-P2- CS(10/Y)200-Cl3 according to EN 13168	4.5 mm x 60 mm with a = 215 mm row distance 625 mm	40-20-40-20-40			

electroni
c copy
troni
elec

	MM – crosslam	Annex 3			
	Resistance to fire	of European Technical Assessment ETA-09/0036 of 21.04.2023			


Γ




Performances E and I – integrity and insulation

The criteria E (integrity) and I (insulation) are considered to be fulfilled if

- the distance between the non-charred bond line and the 300°C isotherm is ≥ 20 mm and
- the residual timber cross-section consists of at least one non-charred bond line and a layer above it.



The design of element joints, e.g. with stepped rebate or top-side cover board, fulfil the criteria E (integrity) and I (insulation) if a residual timber cross-section of 2 cm exists up to the element joint, e.g. stepped rebate or cover board.





Sealing tapes are not required for the above-mentioned joints if

- the surface temperature is < 120°C and
- the maximum distance of the screw connection of 250 mm is observed.
- For stepped rebate joints, the temperature in the rebate area must be < 150°C and the maximum distance of the screw connection must be < 250 mm.

MM – crosslam	Annex 3
Resistance to fire	of European Technical Assessment ETA-09/0036 of 21.04.2023



Mechanical actions perpendicular to plane and in plane of cross laminated timber

<u>General</u>

Due to the perpendicular orientation of the boards, cross laminated timber is able to transfer loads in all directions according to its condition of support.

For calculation of characteristic values of cross-section, only boards which are oriented in direction of the mechanical action may be employed.

For design of cross laminated timber according to EN 1995-1-1, characteristic strength and stiffness of solid wood according to Annex 2 shall be taken. If the cross laminated timber is comprised of visually graded boards, the characteristic bending strength parallel to the grain may be determined with the following equation:

 $f_{m, CLT, k} = Minimum \begin{cases} a_{CLT} \cdot f_{t, 0, k}^{0,8} \\ 1, 2 \cdot f_{m, k} \end{cases}$


b≥1 m

Where

$f_{m, CLT, k}$ MPa characteristic bending strength of cross laminated timber
$f_{m, k}$ MPa characteristic bending strength according to EN 338
a _{CLT} = 3.5 for visually graded timber
$f_{t, 0, k}$ MPa characteristic tensile strength of board according to EN 338
b mm width of the member of cross laminated timber

For cross laminated timber multi-axle stressed in both principal directions, different stiffness for the two principal directions shall be considered.

Mechanical actions perpendicular to cross laminated timber



Where

- *t*_i Thickness of board layers in direction of mechanical actions
- *t*_i Thickness of board layers perpendicular to direction of mechanical actions

The bending stiffness is specified in relation to the effective moment of inertia I_{eff} . The calculation of the effective moment of inertia and therewith of the effective bending stiffness is according to EN 1995-1-1.

MM – crosslam	Annex 4	
Design considerations for cross laminated timber	of European Technical Assessment ETA-09/0036 of 21.04.2023	



For I_{eff} see clause 9.1.3 and Annex B of EN 1995-1-1. The term $\frac{S_i}{K_i}$ of EN 1995-1-1 should be substituted by $\frac{\overline{t_i}}{G_{9090} \cdot b}$. $I_i = \frac{b \cdot t_i^3}{12}$ $W_{eff} = \frac{2 \cdot I_{eff}}{t_{tot}}$ $A_i = b \cdot t_i$ $h_{tot} = \sum_i (t_i + \overline{t_i})$ $\tau_{v, d} = \frac{1, 5 \cdot V_d}{A_{gross}}$ $A_{gross} = b \cdot t_{tot}$

Where

I.....moment of inertia


 I_{eff} effective moment of inertia

s.......... spacing of fasteners according to EN 1995-1-1 (*not relevant for solid wood slab*) *K*......slip modulus according to EN 1995-1-1 (*not relevant for solid wood slab*) *G*₉₀₉₀.....shear modulus of the board perpendicular to grain (*rolling shear modulus*);

G₉₀₉₀ = 50 MPa

b.....width of the member of cross laminated timber

Mechanical actions in plane of the solid wood slab



Where $H \le 400 \text{ mm}$ $t_i.....$ Thickness of board layers in direction of mechanical actions $\overline{t_i}$ Thickness of board layers perpendicular to direction of mechanical actions V...... Shear force

Under the terms of the technical beam theory the following equations may be used.

Moment of inertia

Section modulus

MM – crosslam	Annex 4	
Design considerations for cross laminated timber	of European Technical Assessment ETA-09/0036 of 21.04.2023	



EAD 130005-00-0304, European Assessment Document for "Solid wood slab element to be used as a structural element in buildings"

EN 301 (11.2017), Adhesives, phenolic and aminoplastic, for load-bearing timber structures – Classification and performance requirements

EN 338 (04.2016), Structural timber – Strength classes

EN 520:2004+A1 (08.2009), Gypsum plasterboards – Definitions, requirements and test methods

EN 1995-1-1 (11.2004), +AC (06.2006), +A1 (06.2008), +A2 (05.2014), Eurocode 5 – Design of timber structures - Part 1-1: General – Common rules and rules for buildings

EN 1995-1-2 (11.2004) +AC (06.2006), +AC (03.2009), Eurocode 5 – Design of timber structures – Part 1-2: General – Structural fire design

EN 13162:2012+A1 (02.2015), Thermal insulation products for buildings – Factory made mineral wool (MW) products – Specification

EN 13168:2012+A1 (02.2015), Thermal insulation products for buildings – Factory made wood wool (WW) products – Specification

EN 13183-2 (04.2002), Moisture content of a piece of sawn timber – Part 2: Estimation by electrical resistance method

EN 13986:2004+A1 (04.2015), Wood-based panels for use in construction – Characteristics, evaluation of conformity and marking

EN 14080 (06.2013), Timber structures – Glued laminated timber and glued solid timber – Requirements

EN 15425 (01.2017), Adhesives – One component polyurethane for load bearing timber structures – Classification and performance requirements

EN ISO 10456 (12.2007), +AC (12.2009), Building materials and products – Hygrothermal properties – Tabulated design values and procedures for determining declared and design thermal values

MM – crosslam	Annex 5
Reference documents	of European Technical Assessment ETA-09/0036 of 21.04.2023